



BRUHAT BENGALURU MAHANAGARA PALIKE

Office Of The Medical Officer OF Health Mahadevapura Zone, Bangalore - 48

NO: BBMP/HO/MDP/PR/13/2025-26

DATE:02-05-2025

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

It is certified that an inspection team headed by Dr.Vishveshwaraiah Health Officer (Name of Officers with designation) from BBMP Health Department PHED inspected Orchids The International School, Survey No.25/, 25/2, 25/3 And 25/4, Byrathi - Kyalasanahalli, International Airport Link Road, Bengaluru - 560077 (Name & Address of the school) on 02-05-2025 (date of inspection) and on the basis of Water Test Report (Attached) bearing no PHI/Water/BAC/45/25-26 dated 19-04-2025 of GOVERNMENT OF KARNATAKA (PHED Lab) certified that Orchids The International School (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.


This certificate is valid till 31-03-2026

Signature with Seal

Name : Dr. Vishveshwaraiah
Designation : Health Officer
Department : BBMP, Mahadevapura Zone.

To
Orchids The International School,
Survey No.25/, 25/2, 25/3 And 25/4,
Byrathi - Kyalasanahalli,
International Airport Link Road,
Bengaluru - 560077.

For VIVEKAVARDHINI EDUCATION SOCIETY(R)


PRESIDENT


Principal
Orchids The International School
Byrathi -Hennur Branch.

LOGO

BRUHAT BENGALURU MAHANAGARA PALIKE

Office of the Medical Officer of Health, Mahadevapura Zone, Bangalore – 48.

NO.BBMP / HO / MDP / PR / 13 / 2025-26

DATE: 02-05-2025

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

It is certified that an inspection team headed by **Dr. Vishveshwaraiah Health Officer** (Name of Officers with designation) from **BBMP Health Department** PHED inspected **Orchids The International School, Survey No.25/1, 25/2, 25/3 And 25/4, Byrathi - Kyalasanahalli, International Airport Link Road, Bengaluru – 560077** (Name & Address of the school) on **02-05-2025** (date of inspection) and on the basis of Water Test Report (Attached) bearing no **PHI/Water/BAC/45/25-26** dated **19-04-2025** of **GOVERNMENT OF KARNATAKA** (PHED Lab) certified that **Orchids The International School** (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central / State / U.T. Govt.

This certificate is valid till **31-03-2026**

Signature with Seal: Sd/-
Name : **Dr. Vishveshwaraiah**
Designation: **Health Officer**

Name & Address of the Office / Department : BBMP, Mahadevapura Zone

The Seal of
Health Officer
Bruhat Bengaluru Mahanagara Palike
Mahadevapura Zone,
Bengaluru.

To

Orchids The International School
Survey No.25/1, 25/2, 25/3 And 25/4,
Byrathi - Kyalasanahalli,
International Airport Link Road,
Bengaluru – 560077.


Principal

Orchids The International School
Byrathi -Hennur Branch.

For **VIVEKA VARDHINI EDUCATION SOCIETY(R)**


PRESIDENT

TRANSLATED BY ME


G. DAYANANDA
Advocate & Notary
Govt. of India
61, 2nd Floor, 7th Cross
Malleshwaram Bangalore - 560 003



GOVERNMENT OF KARNATAKA

No:PHI/Water/BAC/ 45/25-26

Office of the Joint Director
Public Health Institute
Bengaluru - 560 001

Dated: 19-04-2025

Report of Bacteriological analysis of Water/Effluent sample

Sample No.	Source & Particulars of Water Sample	Opinion				S.P.P	N.S.P.P	N.S.P.P & FC.
		M.P.N Count	Plate Count	D.C Test				
142	RO Water B. No. 4129470	Nil	—	—		SPP	—	—
<p>Note: M.P.N Count: Most probable number of Bacteria per 100ml of Water D.C Test: Differential Collform test Plate Count: Plate Count per ml of sample SPP: Water is satisfactory for Potable purpose NSPP: Water is not satisfactory for Drinking purpose NSPP & FC: Water is not satisfactory for Drinking purpose and E.Coli found</p>								

Principal

Orchids The International School
Byrathi -Hennur Branch.

For VIVEKAVARDHINI EDUCATION SOCIETY(R)

PRESIDENT

For Joint Director (Labs)
PUBLIC HEALTH INSTITUTE
Bengaluru

(PTO)

Advice:

1. Sample.....

Need effective chlorination before use

2. Sample.....


Need to avoid possible source of faecal contamination and effective chlorination before use
For the purpose of chlorination, Refer the Annexure enclosed.



Principal

Orchids The International School
Byrathi -Hennur Branch.

For VIVEKAVARDHINI EDUCATION SC



PRESIDENT

STANDARD FOR THE DRINKING WATER

		Presumptive Coliform count per 100ml	E coli count per 100 ml
CLASS 1	Excellent	0	0
CLASS 2	Satisfactory	1-3	0
CLASS 3	Suspicious	4-10	0
CLASS 4	Unsatisfactory	Greater than 10	0.1 or More